

4 KW TO 11 KW

"ECO" RANGE OF DOL STARTERS

Manufactured to the highest standards by **TECO**



Thermal overload fitted as standard

Extra N/O and N/C contacts

Complete with Manual or Auto reset capability

Overload and phase protection

FEATURES:- (stock starters)

- IP65 plastic enclosure
- AC3 (Induction motor starting) rating
- 415 Volt 50 Hz 3 phase, coils rated 415 Volt
- CE marked
- Gland entry knockout 20 mm x 2, top and bottom
- Other voltages and single phase available on request

A.C. DIRECT ON LINE STARTERS

with IP 65 plastic enclosure

Catalog number			HNF∐-9			HNF□-11		HNF∐-16		HNF□-18				
Dim	h d h ensions (w x	w > (h x d mm)				90	x184 x	113				100	x194 x	123
Magnetic contactor used			CN-9			CN-11		CN-16		CN-18				
Thermal overload relay used			RHN-10			RHN-10		RHN-10		RHN-10				
AC2 & AC3 (50/60Hz) Power Rating Complying with IEC 60947-4-1			А	KW	HP	А	KW	HP	Α	KW	HP	Α	KW	HF
	Single	110V	10.5	0.55	0.75	10.5	0.55	0.75	13.5	0.75	1	19.5	1.1	1.5
		220V	10.5	1.1	1.5	10.5	1.1	1.5	14	1.5	2	20.5	2.2	- 3
	•	220/230V	11.5	2.5	3.5	12	3	4	16	4	5.5	23	5.5	7.
		380/400V	11	4	5.5	12	5.5	7.5	16	7.5	10	22	11	1
	Three phase	415V	10	4	5.5	11	5.5	7.5	15	7.5	10	21	11	1
		440V	9	4	5.5	11	5.5	7.5	15	7.5	10	21	11	1
		500V	8	4	5.5	9	5.5	7.5	13	7.5	10	19	11	1
		660/690V	6	4	5.5	7	5.5	7.5	10	7.5	10	14	11	1
Instantaneous auxiliary contacts			1 N/O			1 N/O		1 N/O		1 N/O 1 N/C				
Weight (kg)			0.85			0.85		0.85		0.95				

Note: 🗆 : B/ with 1 start and 1 stop/reset push buttons. R/ with only 1 stop/reset push button. Blank/ without any push button.

TECO Australia Pty. Ltd.

Head Office: 335-337 Woodpark Road, Smithfield, NSW 2164 Brisbane Office: 50 Murdoch Circuit, Acacia Ridge, QLD 4110 Melbourne Office: 16 Longstaff Road, Bayswater, VIC 3153 Perth Office: 28 Belgravia Street, Belmont, WA 6104

TECO New Zealand Ltd.

Unit 3, 477 Great South Road, Penrose, Auckland

Ph: (02) 9765 8118 Fax: (02) 9604 9330 Ph: (07) 3373 9600 Fax: (07) 3373 9699 Ph: (03) 9720 4411 Fax: (03) 9720 5355 Ph: (08) 9479 4879 Fax: (08) 9478 3876

Ph: (64) 9 526 8480 Fax: (64) 9 526 8484

Distributed by -			

